ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

INSPECTION CERTIFICATE

File number 20.140.747-2

Issued according to EN ISO/IEC 17020 to the organization:

R-EVC s.r.o.
Mokrá 317, 664 04 Mokrá - Horákov
Czech Republic

On the basis of results conducted on 26.5.2026, which are listed under Inspection Report of TÜV SÜD Czech file No.: 20.140.747-1 and 20.140.749-1 we hereby confirm conformity of the below mentioned device:

Name:	**EcoVolter**
Model:	**Typ 2 – 11kW/ 22 kW**
Type:	**Type- 32 A, IC-CPD**
Serial number:	**REVCR01C00001963**
Power voltage:	**3 +N+PE 400V, 50Hz**
Nominal power:	**22,2kW, 3P+N+PE, 3,7 kW, 1P+N+PE**
Protection class:	**Class II**
Protect cover:	**IP 54**
Manufacturer:	**R-EVC s.r.o., Mokrá 317, 664 04 Mokrá – Horákov, Czech Republic**

With requirements:

ČSN EN IEC 62752 ed.2: 2025 (idt EN IEC 62752:2024):, chapter 9.4, 9.5, 9.6, 9.14, 9.27, 9.25 a 9.35, ČSN EN IEC 61000-4-3 ed.4: 2021 (idt EN IEC 61000-4-3: 2020), ČSN EN 61000-4-4 ed.3:2013 (idt EN 61000-4-4: 2012) , ČSN EN 61000-4-5 ed.3:2015 + A1:2018 (idt EN 61000-4-5: 2014), ČSN EN 61000-4-6 ed.4:2014 (idt EN 61000-4-6: 2014), ČSN EN 61000-4-8 ed.2: 2010 (EN 61000-4-8: 2010), ČSN EN IEC 61000-4-11 ed.3: 2020+Opr.1:2023+ Opr2:2023 (idt EN IEC 61000-4-11: 2020), ČSN EN IEC 61000-3-2 ed.5:2019 + A1: 2021+A2: 2025 (idt EN IEC 61000-3-2: 2019), ČSN EN 61000-3-3 ed.3: 2014+A2: 2022 (idt EN 61000-3-3: 2013)

Valid conditions:

The outcomes of inspection presented in the inspection report are related only to the inspected device; the results are presented in Inspection Reports 20.140.747-1 and 20.140.749-1

In Vejprnice, on 27.5.2026

On behalf of TÜV SÜD Czech s.r.o. : Ing. Michal Svrček, MBA